



Hafren Dyfrdwy Resilience Modelling

Draft Report Severn Trent Water

11 March 2019

Notice

This document and its contents have been prepared and are intended solely as information for Severn Trent Water and use in relation to Draft Report

Atkins Limited assumes no responsibility to any other party in respect of or arising out of or in connection with this document and/or its contents.

This document has 22 pages including the cover.

Document history

		1	1	1	1	
Revision	Purpose description	Origin- ated	Checked	Reviewed	Author-ised	Date
Rev 1.0	Draft report	NU	AS	AS	BC	5 th March 2019
			5			

Contents

Chap	ter	Page
1.	Introduction	4
2.	Dee Catchment Resilience	5
2.1.	Introduction	5
2.2.	Stochastic dataset	5
2.3.	NRW Aquator model	5
2.4.	DGD cut-back post-processing	7
2.5.	Results	8
2.6.	Drought response surfaces	10
3.	Hafren Dyfrdwy inflow generation	10
4.	Deployable output testing	12
4.1.	Approach	12
4.2.	Wrexham RZ	12
4.3.	Chester RZ	16
5.	Conclusions and recommendations	17
Apper	ndices	18
Appen	dix A. NRW VBA changes – RG1 object	19
Table		
Table 2	P-1 – Model DGD parameters applied	6
Table 2	2^{-2} - Options for interpreting the DGD cut-back text	8
Table 2	2 Options for meripicang the DOD cut back text	0
	-5 – Modelling results compared to DGD standards of service	9
Table 4	-1 - Wiexham KZ Scottish Method DO les uits	14
Figure	es	

Figures

Figures		
Figure 1-1 - Key stages of the project	4	
Figure 2-1 - Comparison of Dee catchment stochastic and historic FDCs	5	
Figure 2-2 - Schematic of NRW Dee Aquator model	7	
Figure 2-3 - Custom parameters (in red) added to DC1 component to hold DGD abstractic	n rates	7
Figure 2-4 - Dee (RG1) storage duration curve	9	
Figure 2-5 - Dee (GS1) FDC	10	
Figure 3-1 – HD supply area Aquator model schematic	11	
Figure 3-2 – Stochastic inflow generation process	12	
Figure 4-1 – Wrexham RZ Aquator model schematic	13	
Figure 4-2 - Wrexham RZ relationship between DO and return period (0-1400 year return	period)	15
Figure 4-3 - Wrexham RZ relationship between DO and return period (all results)	16	
Figure 4-4 – Chester RZ Aquator model schematic	17	
Intro		



1. Introduction

The overall objective of this project was to determine the drought resilience of the Hafren Dyfrdwy (HD) supply area, which consists of the Chester and Wrexham Resource Zones (RZ). Deployable output (DO) was determined across a range of drought severities to feed into the Water Resources Management Plan (WRMP) Table 10 Drought Links submission. Additional outputs, for example stochastic flow duration curves (FDC) and drought response surfaces (DRS), were also produced to help inform the Drought Plan.

Supply in the HD area is dominated by abstraction from the River Dee, therefore the drought resilience of this regulated catchment is of paramount importance. Previous assessments using historic hydrological data have demonstrated a high level of resilience. The Dee General Directions (DGD) maximum cut-back, Stage 3, has never been implemented either in practical terms or in model simulations. However, the latest WRMP and Drought Plan guidelines require that companies look beyond historic droughts to plausible "severe" or "extreme" events, with a return period of 1 in 200 years (0.5% annual chance) or 1 in 500 years (0.2% annual chance) respectively.

Fortunately, the project was able to utilise stochastic hydrological data generated for the Dee catchment by Atkins for United Utilities (UU) using a Weather Generator (add footnote). The dataset includes 17,400 years of rainfall and flow data for the following Dee sub catchments:

- Alwen
- Bala
- Brenig
- Celyn
- Manley Hall

These data represent conditions that could have, statistically speaking, happened in the past. As part of the generation process the stochastic probability distributions were matched with the historic ones. Due to the much larger volume of data in the stochastic record, the tails of the distribution are much better represented and therefore provide a range of severe and extreme droughts for assessment.

Natural Resources Wales' (NRW) and Severn Trent Water Limited's (STWL) Aquator water resources models were also made available for the project. As shown in Figure 1-1 below, and described in the following sections, the data and models were combined in a series of stages to determine drought resilience and DO.



Figure 1-1 - Key stages of the project



2. Dee Catchment Resilience

2.1. Introduction

As outlined in Section 1, the Dee stochastic dataset was combined with the NRW Dee Aquator model to help determine the drought resilience of the Dee catchment. In addition to outputs showing the resilience of the catchment, a time series of stochastic DGD cut-backs was derived to use as a boundary condition in the HD model.

2.2. Stochastic dataset

UU provided its stochastic dataset for the Dee catchment, as developed for the 2019 WRMP. The full WRMP19 dataset covers the whole of UU's supply area from Cumbria, through Lancashire, down to Cheshire and North Wales. Of the 12 rainfall gauges used in the Weather Generator, four are located in North Wales.

As a check, FDCs were generated for each of the Dee sub catchments using both the stochastic data and the historic sequences exported from the NRW Aquator model. As shown in Figure 2-1 the fit between stochastic and historic is very strong in all catchments.



Figure 2-1 - Comparison of Dee catchment stochastic and historic FDCs

The 17,400 year stochastic dataset can be thought of as 200 alternative versions of the historic record. Whilst it can be combined into one contiguous sequence, in this project it was split into 10 batches; 00-19, 20-39, 40-59, 60-79, 80-99, 100-119, 120-139, 140-159, 160-179 and 180-199. These batches were used as follows:

- Model setup and testing: 00-19
- Dee NRW model runs: all batches
- HD model DO runs: 00-19, 40-59, 80-99, 120-139, and 160-179

2.3. NRW Aquator model

NRW maintains the Aquator model of the Dee system to assist with its regulatory obligations in the catchment. A schematic of the model is shown in Figure 2-2. The full stochastic dataset was run through the model to determine the resilience of the Dee catchment, and to generate a timeseries of cut-backs for use in stochastic runs of the HD model (Section 4).



Before undertaking the runs it was necessary to update the model to include DGD Stage 3 cut-backs (Stage 3 is not reached in historic runs, hence there was previously no requirement to include it in the model). Custom parameters were added to the DC1 component (Figure 2-3) and additional VBA code was added to the RG1 component to incorporate Stage 3 cut-backs. The code in RG1 was also modified to improve model run speed and is included in Appendix A.

Unlike previous climate change assessments undertaken by NRW, the DGD maximum yield, safe yield and cutback amounts were not adjusted. The stochastic dataset is by design based on the same climatic conditions as the historic dataset (Figure 2-1), therefore there is no rationale to change any of the rules. Climate change impacts were not included in the assessment.

We retained the NRW model assumption that all Dee abstractors always take their maximum DGD entitlement. In reality this is not the case as abstractors also take into account operational rules and costs; these however were not available for the assessment. Also, there would always be the risk that other abstractors altered their operating practices in the future, leading to a lower level of resilience than assessed. Updated DGD cut-back rates were provided by NRW as shown in Table 2-1, along with the River Dee maintained flow condition values applied.

DGD status	Demand (MI/d)	River Dee maintained flow (MI/d)
Maximum abstraction	763	381.979
Safe yield	717.12	381.979
Stage 1	687.12	350.4
Stage 2	657.12	318.821
Stage 3	627.12	318.821

Table 2-1 – Model DGD parameters applied

Due to the volume of data in the stochastic dataset it was not possible to manually load the inflow timeseries into the model database and undertake a single run. Using scripts previously developed by Atkins, the following automated process was undertaken:

- Make multiple copies of the Aquator database
- Load a proportion of the stochastic dataset into each copy
- Select key output variables (reservoir storage and river flow)
- Run the models in parallel, export the selected data and delete the models

This process was undertaken in two parts (half of the stochastic dataset in each), each taking about 20 hours to complete.





Figure 2-2 - Schematic of NRW Dee Aquator model

C1 /Lawer Day	Demand) Use this (Aug 2016)																	
CT (LOWER DE	e Demand) - Ose this (Aug 2010)																	
operties <u>P</u> aram	neters <u>S</u> tates Seguences <u>V</u> ar	iables															Help	<u>C</u> lo
t-click on a cell	in the Value column to start edit, rig	ht-click to edit c	other se	t or component values														
Group	Name	Units	V	Value	at	c	d e	f	3 h	i	i	k	Th	m	n c	No	tes	
otions	Trace flags		&ł	10000000														
	Advance order			1														
Imponent	Demand order			1														
	Demand	MI/d		763.000										Т				
eneral	Demand factor			1.000														
	Apply demand saving		Tr	ue														
a	If demand not met		Tr	ue														
311	Criterion	%		0.10														
	No Cutbacks (VBA)	MI/d		763.000					Т					Т				
	Stage 1 Cutbacks (VBA)	MI/d		687.120					Т					Т				
Demands	Stage 2 Cutbacks (VBA)	MI/d		657.120														
	Stage 3 Cutbacks (VBA)	MI/d		627.120														
	Safe Vield (VRA)	MDA		717 120														

Figure 2-3 – Custom parameters (in red) added to DC1 component to hold DGD abstraction rates

2.4. DGD cut-back post-processing

The NRW model applies cut-backs immediately once Dee storage passes below the corresponding storage curve. In the DGD text, however, delays are applied between crossing the curve and applying the cut-back:

"Stage 1: system storage below stage 1 control curve for 2 consecutive months, during the months March to October.

Stage 2: system storage below stage 2 control curve for a month after stage 1 is already in place, during the months March to September.

Stage 3: system storage below stage 3 control curve for a month after stage 2 is already in place, during the months March to September."

The rules were applied retrospectively to the model results, using simulated storage from the run, before assessing resilience and generating the cut-back sequence for the HD model. Some difficulties were experienced in converting the written rules into logical code, therefore three interpretations were formulated and tested. A description of each option is provided in Table 2-2, along with the corresponding results in terms of



the return periods of implementation. A corresponding run using the historic inflows was also completed for context.

Following discussion with STWL and NRW, Option 1 was taken forward in the assessment. It is recommended that in the future the NRW Dee model is updated to reflect the DGD text. Although the rules were incorporated into this assessment via post-processing, the effects are only partial as the cut-back demand reductions were still applied as the soon as the curves are crossed. This means that storage levels, and therefore resilience levels, are overstated by the model.

Some review of the rules themselves could also be beneficial. One notable effect of the long 1-2 month delays, as interpreted here, is that the simulated frequency of entering into emergency storage is higher than that of implementing stage 3 cut-backs (Table 2-3), i.e. emergency storage would be entered before the cut-back was applied.

Inflows	Stochastic	Historic (1927- 2016)		
Rules approach	Option 1	Option 2	Option 3	No lag on previous stages
	No lag on previous stages	Lag applied consecutively from March	Lag applied consecutively from January	
	For example, Stage 3 cutback is applied if storage is below the stage 3 curve for 30 days between Mar- September, irrespective of what has happened with stages 1 and 2.	For example, Stage 3 cutback is only applied once Stage 1 has been in place for 60 days and Stage 2 in place for 30 days. Stage 1 cannot start until March. No cutback is applied after September.	As per March but Stage 1 can start in January. No cutback is applied after September.	
Below stage 1 curve	1 in 7 years	1 in 8 years		
Below stage 2 curve	1 in 13 years	1 in 11 years		
Below stage 3 curve	1 in 54 years	1 in 46 years		
Below emergency storage	1 in 212 years	N/A		
Stage 1 cutbacks implemented	1 in 24 years	1 in 24 years	1 in 21 years	1 in 46 years
Stage 2 cutbacks implemented	1 in 38 years	1 in 81 years	1 in 70 years	1 in 91 years
Stage 3 cutbacks implemented	1 in 311 years	1 in 512 years	1 in 446 years	N/A

Table 2-2 - Op	tions for interp	preting the DG	O cut-back text
----------------	------------------	----------------	-----------------

2.5. Results

The results of assessment were compared against the DGD standards of service, as shown in Table 2-3. The service levels are met for Stage 2 but not quite met for Stage 2 (1 in 38 years versus 1 in 40 years). Note that the HD temporary use ban (TUBs) service level of 1 in 40 years is linked to Stage 3. The DGD also has a 60 month refill target. We anticipate that it may not be met at times due to the severity of some stochastic droughts. However, as there is no return period linked to this target we did not undertake testing; it would be difficult to put any stochastic failures into context. Also, as previously mentioned there was no intention to adjust any of the DGD rules, such as the safe yield amount.



Inflows	Simulated return period	DGD standards of service							
Stage 1 cutbacks implemented	1 in 24 years	1 in 10 years							
Stage 2 cutbacks implemented	1 in 38 years	1 in 40 years							
Stage 3 cutbacks implemented	1 in 311 years	Not specified							
Below emergency storage	1 in 212 years	N/A							

Table 2-3 - Modelling results compared to DGD standards of service

Storage duration curves and FDCs were also generated to help demonstrate the resilience of the Dee catchment; they are shown in Figure 2-4 and Figure 2-5 respectively. The storage duration curve shows that the Dee reservoirs (RG1 corresponds to the Celyn and Brenig storage combined) could plausibly become empty during an extreme drought. However, flow downstream of the abstraction point, as represented by the FDC, always remains above 318 Ml/d. This flow is consistent with the Stage 2 / 3 maintained flow requirement (Table 2-1), demonstrating that even during the most severe conditions, when Celyn and Brenig storage is exhausted, there is still flow in the catchment.



Figure 2-4 - Dee (RG1) storage duration curve









3. Hafren Dyfrdwy inflow generation

Whilst supply to HD customers is dominated by abstraction from the River Dee there are other sources of supply, as shown in the Aquator model schematic below (Figure 2-5). The groundwater sources are considered to be resilient to drought and constrained only by asset capacity or licence. However, there are several impounding reservoirs in the Wrexham RZ which could be vulnerable to severe or extreme droughts.





Figure 3-1 – HD supply area Aquator model schematic

As noted in the Atkins model development report¹ the inflows to these surface water sources are ungauged. Therefore, inflows were inferred using flow from gauging stations with similar catchment characteristics. The principle gauge used was Ceiriog at Brynkinalt Weir (67005). NRW's Brenig flow sequence (as used in the Dee Aquator model) was used to infill periods where the Ceiriog data quality was poor.

The method used was to sample the FDCs of the ungauged location, as extracted from the Low Flows Enterprise (LFE) software, and the gauged location. A similar approach was used here to generate stochastic inflows for the Wrexham RZ sources. As Brenig had previously been selected for use due to its hydrological similarity to the Wrexham RZ catchments it was again used here. New data points were included in the extremities of the FDCs to reflect the extra information available from the stochastic dataset. The full process is shown below in Figure 3-2. It was only undertaken for the half of the stochastic dataset used in the DO testing (Section 1).

¹ Aquator model audit and review, Dee Valley Water, March 2017





Figure 3-2 - Stochastic inflow generation process

4. Deployable output testing

4.1. Approach

As noted in Section 1, the main objective of the project was to determine the relationship between DO and drought severity / return period. The Aquator Scottish Method DO analyser was used for this purpose. It is similar to the English and Welsh method but rather than focussing on the demand that can be met without any failures, the number of failures is counted up across a range of demands. The demand interval and window is specified by the user. This results in a matrix of demand failure levels and number of years failure which can then be translated into a relationship between DO and return period (Figure 4-2).

This type of run is very computationally demanding, hence is was infeasible to utilise the full stochastic dataset. The results of the NRW Dee Aquator model runs were used to help determine the volume of stochastic data required to produce results that were representative of the full dataset. As noted in Section 1, the stochastic dataset was spilt into 10 batches and the model results - return periods of stage 1, 2 and 3 cut-backs and breaching emergency storage - from each batch were compared. Using just one batch did not represent the full stochastic dataset well. However, using any combination of half of the results represented the full dataset effectively. Therefore, as introduced in Section 1, alternate batches were selected for use.

Owing to the nature of the supply system, the modelling work was focussed on the Wrexham RZ. The drought resilience of the Chester RZ can simply be derived from the ability of Pen Y Cae to augment the River Dee during cut-backs (Section 4.3).

4.2. Wrexham RZ

4.2.1. Input data preparation

The reservoir inflow data were prepared as described in Section 3. As shown in Figure 3-1, the Dee system is included in the model as a river only, with no simulation of the Dee reservoir storage further up the catchment. Inflow to the Dee catchment is unconstrained (a daily profile of 9999 MI/d is used) but the intake capacity is limited to either the maximum abstraction or the safe yield (45.5 or 41.5 MI/d respectively) based on a sequence imported into the model. A new sequence was generated for this purpose based on the simulated Dee storage levels from the stochastic run (Section 2.3).



When stage 1, 2 or 3 cut-backs are enforced Pen Y Cae Lower reservoir is used to augment the River Dee (rates of 0.4, 0.8 and 1.2 Ml/d respectively, to cover both RZs), so that the safe yield level of abstraction can be maintained. Therefore, testing this augmentation process was key to determining the resilience of the HD supply. A sequence of augmentation amounts was also created using the simulated Dee storage levels from the stochastic run. As per the original configuration, flow rates of 1.2 Ml/d were applied on the first two days of augmentation to represent channel wetting. Note that the results of the assessment are not sensitive to this assumption.

4.2.2. Model preparation

As noted above, modelling was focussed on the Wrexham RZ. To reduce model complexity, and run time, the Chester RZ portion of the model was removed to create a Wrexham RZ model. The schematic is shown below in Figure 4-1.



Figure 4-1 – Wrexham RZ Aquator model schematic

Using the first batch of stochastic inflows (00-19) significant testing was undertaken to ensure that the model was able to respond to the severe and extreme droughts in a sensible manner. A number of control curves were adjusted and the resilient Dee and Llangollen / Oerog Springs sources were encouraged to abstract as much water as possible using minimum flow constraints. At lower demands (40-50 M/d) the changes were effective and the number of failures (i.e. emergency storage breaches or demand shortfalls) were reduced. At higher demands, however, the number of failures was increased. This was not investigated in detail but was likely due to the minimum flow conditions which can cause problems for the Aquator optimiser if they cannot be met at high levels of system stress.

Unfortunately, the HD Aquator model is not configured to apply the demand savings associated with the implementation of TUBS or non-essential use bans (NEUB). TUBs restrictions are linked to DGD Stage 3; as this is not reached it historic runs there was no past requirement to include this in the model. Also, demand saving in Aquator is normally by enacted by simulating reservoir storage passing below a drought curve. However, the Dee storage is not simulated in the HD model. There are other ways to implement this, for example VBA to modify the demand saving level based on the sequence used for Pen Y Cae augmentation, which is itself based on the DGD stage. Unfortunately, there was insufficient time available to implement this within the project. It is recommended that this work is undertaken in the future; it would lead to higher DO results for a given return period.

As per the original HD model configuration, the use of emergency storage was not permitted during runs.



4.2.3. Results

Whilst this RZ is dominated by supply from the River Dee, drought resilience can be affected by other sources. These sources have a high level of drought resilience, but not quite matching that of the River Dee. During plausible drought events hydrology, rather than asset capability / licence, can become the DO constraint.

The results from the Scottish Method DO runs are shown in Table 4-1 below, by batch and combined. A further processing step was applied to combine failures occurring in consecutive years into a single failure. The assumption was that in the majority of cases this would be representative of a single, multi-year drought. In any case this had a relatively limited effect on the results. It is recommended that further analysis of some of the individual stochastic droughts is conducted in the future.

The results across the 1700-year batches are relatively consistent but there are some differences, particularly in batch 120-139. The relationship between DO and return period is shown graphically at two different scales in Figure 4-2 and Figure 4-3. The historic asset capacity / licence based DO of 51.2 Ml/d has a return period of 1 in 44 years once a larger selection of hydrological events is used. The return period of an event which would threaten supply at dry year demand plus target headroom² is only around 1 in 1,200 years. The 1 in 200 year DO is 50.1 Ml/d and the 1 in 500 year DO is 49.0 Ml/d.

Failure demand	Stochastic return period (years)									
(MI/d)	00-19	40-59	80-99	120-139	160-179	Combined (8,700 years)				
39	No failures	No failures	No failures	No failures	No failures	No failures				
40	1740	1740	1740	No failures	No failures	2900				
41	1740	1740	1740	No failures	No failures	2900				
42	1740	1740	1740	No failures	No failures	2900				
43	1740	1740	1740	No failures	No failures	2900				
44	870	1740	1740	No failures	1740	1740				
45	580	1740	1740	No failures	1740	1450				
46	580	1740	1740	No failures	1740	1450				
47	580	1740	870	No failures	870	1088				
48	348	870	870	No failures	870	791				
49	348	435	435	1740	580	512				
50	290	249	193	193	193	218				
51	70	62	54	76	50	61				
51.2	50	48	40	44	39	44				
52	1	1	1	1	1	1				

Table 4-1 - Wrexham RZ Scottish Method DO results

² 46.46 MI/d, from the year 2020/21 in the Final WRMP





Figure 4-2 - Wrexham RZ relationship between DO and return period (0-1400 year return period)





Figure 4-3 - Wrexham RZ relationship between DO and return period (all results)

4.3. Chester RZ

A Chester RZ model was created but not used in the assessment. As shown in Figure 4-4, the only sources in the RZ are the River Dee and Mickle Trafford borehole. The borehole is resilient to drought and the River Dee abstraction is protected from DGD cut-backs by augmentation from Pen Y Cae Lower in the Wrexham RZ, as shown in Figure 4-1.

Therefore, the testing undertaken for the Chester RZ was to run all of the stochastic data prepared for DO modelling (i.e. half of the batches, 8,700 years) through the Wrexham RZ model with a demand of 51.2 Ml/d. This represents the English and Welsh method DO of the Wrexham RZ and is constrained only by asset capacity / abstraction licence. It is well above forecast demand and target headroom for the RZ (46.46 Ml/d).

Augmentation from Pen Y Cae Lower reservoir was fully maintained throughout all plausible severe and extreme droughts. Therefore, the Chester RZ was deemed to be resilient to plausible severe and extreme droughts, and the DO at all return periods is consistent with the historic, asset capacity / licence-based DO of 29.3 Ml/d.

Due to the reliance on sources situated in the Wrexham RZ, further review of the connectivity / risk equivalence between the two RZs is recommended at the next RZ integrity test.





Figure 4-4 – Chester RZ Aquator model schematic

5. Conclusions and recommendations

Owing to the nature of the Dee catchment the HD supply area is very resilient to drought. In the Chester RZ the severe and extreme plausible droughts tested did not impact DO. In the Wrexham RZ some of the other sources are slightly less resistant to drought, but the level of resilience is still very high. The 1 in 200 and 1 in 500 year DO results of 50.1 and 49.0 MI/d are lower than the existing historic based English DO of 51.2 MI/d, but significantly higher than dry year demand of 46.46 MI/d (including target headroom).

This assessment was completed in relatively short period of time. Despite this the method of determining DO for plausible severe and extreme droughts is very robust, and in line with industry-leading practices. As noted in previous sections, there are a few recommended areas for further review or assessment:

- Review the timing of the implementation of DGD cut-backs in the Aquator simulation of Dee storage application of delays.
- RZ integrity review of the links between the Wrexham and Chester RZs common reliance on the River Dee and Pen Y Cae.
- Re-assess DO with TUBs demand restrictions implemented during Stage 3 cut-back periods. Consider how NEUBs are represented.
- Conduct some more detailed analysis of individual stochastic drought events.

Appendices



Appendix A. NRW VBA changes – RG1 object

Option Explicit

```
' To hold the value and date of min storage during a run
Private m fMinStorage As Single
Private m_dtMinStorage As Date
Private RG Supply CC As IAquator.IProfile
Private DS1 CC As IAquator.IProfile
Private DS2 CC As IAquator. IProfile
Private DS3 CC As IAquator.IProfile
Private Dem NoCutback As Single
Private Dem SafeYld As Single
Private Dem Stage1 As Single
Private Dem Stage2 As Single
Private Dem Stage3 As Single
Private HOF NoCutback As Single
Private HOF SafeYld As Single
Private HOF Stage1 As Single
Private HOF Stage2 As Single
Private HOF Stage3 As Single
Private Sub ReservoirGroup AfterInitialize (ByVal StartDate As Date, ByVal Steps As Long)
    ' Invalidate results at start of run
   m fMinStorage = 300000
   m dtMinStorage = CDate(0)
    'Set curves to control behaviour
   Set RG Supply CC = Me.Q ControlCurve.ActiveProfile
   Set DS1 CC = Me.Q DemandSavingCurve(1).ActiveProfile
   Set DS2 CC = Me.Q DemandSavingCurve(2).ActiveProfile
   Set DS3 CC = Me.Q DemandSavingCurve(3).ActiveProfile
    'Set constraint and demand values from parameters
   Dem NoCutback = Model.Components("DC1").Parameters("Demands.No Cutbacks (VBA)").Value
   Dem SafeYld = Model.Components("DC1").Parameters("Demands.Safe Yield (VBA)").Value
   Dem Stage1 = Model.Components("DC1").Parameters("Demands.Stage 1 Cutbacks (VBA)").Value
    Dem Stage2 = Model.Components("DC1").Parameters("Demands.Stage 2 Cutbacks (VBA)").Value
   Dem Stage3 = Model.Components("DC1").Parameters("Demands.Stage 3 Cutbacks (VBA)").Value
   HOF NoCutback = Model.Components ("GS1").Parameters ("Flow constraint.No cutbacks
(VBA)").Value
   HOF SafeYld = Model.Components("GS1").Parameters("Flow constraint.Safe yield
(VBA)").Value
   HOF Stage1 = Model.Components("GS1").Parameters("Flow constraint.Stage 1 Cutback
(VBA)").Value
   HOF Stage2 = Model.Components("GS1").Parameters("Flow constraint.Stage 2 Cutback
(VBA)").Value
```



```
HOF Stage3 = Model.Components("GS1").Parameters("Flow constraint.Stage 3 Cutback
(VBA)").Value
End Sub
'temporarily block out below for yield search (comment block), see code on DC1
   Private Sub ReservoirGroup BeforeStartDay(ByVal Timestamp As Date, ByVal Step As Long,
DemandSaving As Single)
    'limit abstraction when system storage is below safe yield, S1 & S2 drought lines
        Dim fControlCurveValue As Single 'Safe yield
        Dim fLevel1CurveValue As Single 'cutback stage 1
        Dim fLevel2CurveValue As Single 'cutback stage 2
        Dim fLevel3CurveValue As Single 'cutback stage 3
        'get control curve value
        Call RG Supply CC.GetDataForDay(Timestamp, fControlCurveValue)
        'If system storage < safe yield abstract safe yield other wise take max authorised
        If Me.V StorageCalculatedPC > fControlCurveValue Then
            DC1.P Demand = Dem NoCutback
            AB1.P FlowConstraintValue = HOF NoCutback
        Else
            'get control curve value
            Call DS1 CC.GetDataForDay(Timestamp, fLevel1CurveValue)
            If Me.V StorageCalculatedPC > fLevel1CurveValue Then
                DC1.P Demand = Dem SafeYld
               AB1.P FlowConstraintValue = HOF SafeYld
            Else
                'get control curve value
                Call DS2 CC.GetDataForDay (Timestamp, fLevel2CurveValue)
                If Me.V StorageCalculatedPC > fLevel2CurveValue Then
                    DC1.P Demand = Dem Stage1
                    AB1.P FlowConstraintValue = HOF Stage1
                Elsê
                    get control curve value
                    Call DS3 CC.GetDataForDay(Timestamp, fLevel3CurveValue)
                    If Me.V StorageCalculatedPC > fLevel3CurveValue Then
                        DC1.P Demand = Dem Stage2
                        AB1.P FlowConstraintValue = HOF Stage2
                    Else
                        DC1.P Demand = Dem Stage3
                        AB1.P FlowConstraintValue = HOF Stage3
                    End If
               End If
            End If
        End If
   End Sub
```

Private Sub ReservoirGroup_BeforeTerminate()



```
' Report min storage in model run log at end of run
Call Model.AddLog(aqtLogInformational, "RG1", "Min storage = " & Format$(m_fMinStorage,
"0") & " on " & Format$(m_dtMinStorage, "dd mmm yyyy"))
End Sub
Private Sub ReservoirGroup_AfterTerminateDay(ByVal Timestamp As Date, ByVal Step As Long,
AmountAdded As Single, AmountStored As Single, AmountLeaked As Single, AmountLost As
Single, Cost As Single, Status As IAquator.aqtStatus)
 ' Check for min storage each day
 If Me.V_StorageCalculatedQ < m_fMinStorage Then
    m_fMinStorage = Me.V_StorageCalculatedQ
    m_dtMinStorage = Timestamp
  End If
 'temporarily block out below for a yield search, see code on DC1 for yield search
```

```
set emergency storage (30 day storage reserve) at 27475 Ml and fail if used
```

If Me.V_StorageCalculatedQ < 27475 Then

```
Call Model.AddLog(aqtLogFailure, "RG1", "run failure - below storage reserve")
Status = aqtStatusFailure
```

End If

End Sub



Neil Upton Atkins Limited Chadwick House Birchwood Park Warrington WA3 6AE

Tel: +44 (0)1925 238000 neil.upton@atkinsglobal.com

© Atkins Limited except where stated otherwise