

# The water supply

## (water fittings) regulations 1999

Contact Details	
Company Name	
Address	
Telephone	
Mobile	
Email	

Site Details	
Site contact name	
Site address	
Telephone	
Email	

Declaration					
Print name:		Signed:		Date:	

**Please submit all Regulation 5 notification forms to the Water Fittings Regulations Team.**  
Post them to us: Water Fittings Regulations Team, Hafren Dyfrdwy, PO Box 51, Endeavour House, Raynesway, Derby, DE21 7JA. Or email them to [water.regulations@hdcymru.co.uk](mailto:water.regulations@hdcymru.co.uk)

**Please also enclose the following items with this notification:**  
1) map detailing the location of the proposed work  
2) schematic diagram (showing fittings and pipe work)  
3) list of proposed fittings, materials and appliances to be installed



severn dee

## Regulation 5 (Reason for notification)

Tick

1. The erection of a building or other structure, not being a pond or swimming pool.
2. The extension or alterations of a water system on any premises other than a house.
3. A material change of use of any premises.
4. The Installation of:
  - a) a bath having a capacity, as measured to the centre line of overflow, of more than 230 Litres;
  - b) a bidet with an ascending spray or flexible hose;
  - c) a single shower unit (which may consist of one or more shower heads within a single unit), not being a drench shower installed for reasons of safety or health, connected directly or indirectly to a supply pipe which is of the type specified by the regulator;
  - d) a pump or booster drawing more than 12 litres per minute, connected directly or indirectly to a supply pipe;
  - e) a unit which incorporates reverse osmosis;
  - f) a water treatment unit which produces a waste water discharge or which requires the use of water for regeneration or cleaning;
  - g) a reduced pressure zone (RPZ) valve assembly or other mechanical device for protection against a fluid which is in fluid category 4 or 5;
  - h) a garden watering system unless designed to be operated by hand; or
  - i) any water system laid outside a building and either less than 750mm or more than 1350mm below ground level.
5. The construction of a pond or swimming pool with a capacity greater than 10,000 litres which is designed to be replenished by automatic means and is to be filled with water supplied by a water undertaker.

## Regulation 6 (Contractors certificate)

- 1) Where a water fitting is installed, altered, connected or disconnected by an approved contractor, the contractor shall upon completion of the work furnish a signed certificate stating whether the water fitting complies with the requirements of these Regulations to the person who commissioned the work.
- 2) In the case of a fitting for which notice is required under paragraph 5 above, the contractor shall send a copy of the certificate to the water undertaker.

Further interpretation and advice can be found on the WRAS website: [www.wras.co.uk](http://www.wras.co.uk)

**HAFREN**

**DYFRDWY**

severn dee